

Schedule of Accreditation

issued by

United Kingdom Accreditation Service

21 - 47 High Street, Feltham, Middlesex, TW13 4UN, UK

 <p>4439</p> <p>Accredited to ISO/IEC 17025:2005</p>	<h3>Thomas Bell-Wright International Consultants</h3>	
	<p>Issue No: 002 Issue date: 16th August 2010</p>	<p>PO Box 26385 No 81 25b St. Community 613 Al Aweer Industrial Area Dubai UAE</p>
<p>Testing performed at the above address only</p>		

DETAIL OF ACCREDITATION

Materials/Products tested	Type of test/Properties measured/Range of measurement	Standard specifications/ Equipment/Techniques used
BUILDING CONSTRUCTION COMPONENTS AND MATERIALS	Fire resistance (General Requirements)	BS 476 :Part 20:1987 EN 1363-1:1999 EN 1363-2:1999 ISO 834-1 :1999
FIRE DOORS AND SHUTTERS	Fire resistance	EN 1634-1:2008 BS 476 :Part 22:1987:Section 6, 7 and 8 ISO 3008:2007 UL10B:2009 UL10C:2009 NFPA 252:2008
WALLS AND PARTITIONS - non load bearing	Fire resistance	EN 1364-1:1999 BS 476 :Part 22:1987 : Section 5 ISO 834-8:2002 ASTM E119-09C NFPA 251:2006 UL 263:2007
MARINE CONSTRUCTIONS – bulkheads, doors and windows	Fire resistance	IMO Resolution A.754(18): 1993
GLAZING	Fire resistance	BS 476 :Part 22:1987 : Section 10 ISO 3009:2003 NFPA 257:2010
DAMPERS	Fire resistance	UL 555:2006 (fire test only)
HOSE STREAM APPLICATION	Integrity of building elements after fire exposure	ASTM E2226-10



4439

Accredited to
ISO/IEC 17025:2005

Schedule of Accreditation
issued by
United Kingdom Accreditation Service
21 - 47 High Street, Feltham, Middlesex, TW13 4UN, UK

Thomas Bell-Wright International Consultants

Issue No: 002 **Issue date:** 16 August 2010

Testing performed at main address only

Materials/Products tested	Type of test/Properties measured/Range of measurement	Standard specifications/ Equipment/Techniques used
CONSTRUCTION PRODUCTS AND BUILDING ELEMENTS	Fire classification	EN 13501-2:2007
END		